



A RIPLEY® BRAND

DLS 655

Multi Light Source
User Guide




Contents

Introduction	3
Device Overview	3
Important Safety Information	4
Understanding the Main screen	5
Modes	6
Settings	7
Dual Adapter Light Sources	8
Certifications and Contact Information	9

Introduction

The DLS 655 is an optical laser source used for verifying the proper function of fiber optic networks. This document will serve as an overview of the major functions and features of the device.

Device Overview



Important Safety Information



Read and understand all of the instructions and safety information in this manual before operating this tool.



Laser Hazard

Avoid eye exposure to open fiber connectors and interfaces when working with fiber systems. They may be connected to a live laser source.

Do not look into the output port of a Laser.

Point fiber endfaces toward non-reflective surfaces to prevent reflection of laser.



Electric Shock Hazard

Pay attention to proper battery polarity. Do not mix battery types or manufacturers.

Do not open the unit with the exception of the battery compartment door.

Use this unit only for its intended purpose as outlined in this document.



Damage to Item Hazard

Do not leave item in direct sunlight or near heat sources, submerge in water, or subject unit to strong impact.


Cover the fiber interface with the flip-cap when not in use.



Do not throw this product away.

Contact your local recycling station to dispose of properly.

Understanding the Main screen





The Main screen of the DLS 655 acts as the general user interface for fiber testing.

Up to two wavelengths may be transmitted on a single output port at the same time.

When a single wavelength is selected for transmission, only that wavelength will be shown onscreen. Both wavelengths will be shown onscreen only when they are both selected for transmission.


Modes

Press the OK/Menu button to access the Main Menu



Use the Up/Down arrow buttons to move the cursor to the option you would like to explore. Press the Left arrow button to go back to the Main screen. Press the OK/Menu button or the Right arrow button to select an option.

Press the OK or Right arrow button to select the Mode menu.



The Mode menu shows all modulation modes the DLS 655 can transmit.

CW indicates the continuous wave mode. This mode contains no modulation. CW mode can be used with any optical power meter.


Wave-ID indicates the automated wavelength identification mode. In this mode, the DLS 655 wavelength information is transmitted and can be recognized by the RP 560-series of optical power meters. The RP 560 will automatically switch to measure the wavelength being transmitted.

2kHz, 1kHz, and 270Hz are all modulated signals that may be needed for continuity testing on fiber. Any Ripley power meter will identify a 2kHz tone, but the 1kHz and 270Hz options are only compatible with the RP 560-series.

The currently-selected option is highlighted.


Settings

Press the OK/Menu button to access the Main Menu



Use the Up/Down arrow buttons to move the cursor to the option you would like to explore. Press the Left arrow button to go back to the Main screen. Press the OK/Menu button or the Right arrow button to select an option.

Press the OK or Right arrow button to select the Backlight menu.



The backlight menu displays the options for the screen light timer.

Use the Up/Down arrow buttons to move the cursor to the option you would like to select.

Use the OK/Menu or Right arrow button to activate the option. The currently-selected option will be highlighted.


The backlight will turn on each time a button is pressed on the DLS 655. The timer option indicates how long it is illuminated.

Dual Adapter Light Sources

On Dual Adapter/Quad light sources, only one output can be active at a time. The currently active/enabled output will be indicated on the main display by "Right" or "Left" as shown below.

Press the Left arrow button while on the main screen to switch to the Left output.

Press the Right arrow button while on the main screen to switch to the Right output.



Specifications

SINGLEMODE/MULTIMODE LIGHT SOURCE	
Wavelength	Several options available, see chart below
Output Power	-5.0 dBm (SM), -22.0 dBm (MM)
Output Stability	±0.05dB (1 Hour) ±0.03dB Long-Term (15 min warm-up)
Spectral Width	5nm (SM), 40nm / 120nm(MM)
Optical Interface	SC/FC/ST/LC Interchangeable
Tone Output	2 kHz, 1kHz, 270Hz
Class	Class 1 (FDA 21 CFR 1040.11) (SM), Class 1 (IEC 62471:2006)(MM)
Power	Push Button Toggle
Battery	AA - 2 Alkaline Batteries Included
Operating Temperature	-10° to +50° C
Storage Temperature	-30° to +60° C

Ordering Information

PART NO.	WAVELENGTHS	DESCRIPTION
DLS655	1310nm & 1550nm	Singlemode dual wavelength laser source
DLS655-01	1310nm, 1490nm, & 1550nm	Singlemode triple wavelength laser source
DLS655-02	1310nm, 1550nm, & 1625nm	Singlemode triple wavelength laser source
DLS655-03	1490nm & 1625nm	Singlemode dual wavelength laser source
DLS655-04	1550nm & 1650nm	Singlemode dual wavelength laser source
DLS655-05	850nm, 1300nm, 1310nm, & 1550nm	Singlemode and Multimode quad laser source
DLS655-06	1310nm, 1550nm, 1490nm & 1625nm	Singlemode quad wavelength laser source

Accessories

Light Source Adapters

PART NO.	DESCRIPTION
AC 022B	SC Adapter
AC 023B	FC Adapter
AC 024B	ST Adapter

Cleaning Tools

PART NO.	DESCRIPTION
AC 089	One-Click Cleaner for 1.25mm & ODC Ferrules / Bulkheads
AC 099	One-Click Cleaner for 2.5mm Ferrules / Bulkheads
AC 090	1.25mm Swabs (100 per Pack)
AC 091	2.5mm Swabs (100 per Pack)
AC 092	SqR Pad & Fiber Wash Pen
AC 190	Cletop Cleaner - Type B - Blue Tape

Patch Cord Accessories

PART NO.	DESCRIPTION
AC 500	SM SC-LC - 1m Simplex
AC 501	SM SC-SC - 1m Simplex
AC 502	SM LC-LC - 1m Simplex
AC 600	SC-SC Simplex Bulkhead Adapter

Certifications and Contact Information



This product conforms with health, safety, and environmental protection standards for products sold within the European Economic Area (EEA). This product was tested by an ISO 17025 accredited laboratory and complies with the following CE directives and standards listed below:

Directives:

Electromagnetic Compatibility (2014/30/EU)

Low-Voltage (2014/35/EU)

Standards:

EMC: EN 61326-1:2013 Industrial

Safety: EN/IEC61010-1:2010+A1:2016




This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy, and if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

Contact Support

contact us with any questions pertaining to this or any other Ripley product.

 **Call Us:**
(603) 524-8350

 **Email Us:**
tech.support@odm.ripley-tools.com

 **Visit Us Online:** www.ripley-tools.com